SUMTER COUNTY BOARD OF COMMISSIONERS
EXECUTIVE SUMMARY

SUBJECT: 3rd Amendment to the Fire and Security Alarm Contract with VSC Fire & Security (Staff recommends approval).

REQUESTED ACTION: **Approve**

☐ Work Session (Report Only) **DATE OF MEETING:** **10/23/12**
☒ Regular Meeting ☐ Special Meeting

CONTRACT: ☐ N/A Vendor/Entity: VSC Fire & Security
Effective Date: 10/23/12 Termination Date: 08/09/13
Managing Division / Dept: Public Works Division / Facilities Maintenance Department

BUDGET IMPACT: $40,000.00
☒ Annual **FUNDING SOURCE:** County Buildings
☐ Capital **EXPENDITURE ACCOUNT:** 001-100-519-3400
☐ N/A

HISTORY/FACTS/ISSUES:

- **VSC Fire & Security was contracted on August 10, 2010 to provide Fire and Alarm Security services and repair to various County owned buildings. The contract allows for (2) additional one year term renewals.**
- **This 3rd amendment will include the following scope of service for work that is performed but not included in the original contract.**

Unforeseen Sprinkler Repairs

1. Broken sprinkler head
2. Bad valve
3. Bad flow switch
4. Bad water gong
5. Bad flow or damaged back flow

Fire Alarm Panels

1. Bad pull station
2. Bad smoke detector
3. Bad strobe
4. Bad Batteries
5. Power surge blown panel
6. Cut wire

Hoods

1. Bad motor
2. Discharge of system
3. Bad Detectors

Extinguishers

1. Out of date and can not certify
2. Needs to be recharged after use
3. Adding one to new location

New Buildings

1. New extinguishers
2. New hoods
3. New fire alarm panel
4. New sprinklers